

# Annual Drinking Water Quality Report

## Pittsboro Water Company

IN5232020

Annual Water Quality Report for the Period of January 1 to December 31, 2022.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by PITTSBORO WATER COMPANY is purchased surface water from Citizens Water. All Source Water Assessment Plans (SWAP) or Well Head Protection Plan (WHPP) should be obtained through Citizens Water. The other source of drinking water used by PITTSBORO WATER COMPANY is groundwater well on site.

For more information regarding this report contact:

Name: Gary Golay, Water Works Operator: WT3/DSL

Phone: 317-892-3326

If you would like to learn more, please attend any of our regularly scheduled town council meetings. They are held on the third Tuesday of every month at 7:00 pm.

Este informe contiene información muy importante sobre el agua que bebe. Tradúzcalo ó hable con alguien que lo Entienda bien.

### Source Water Information

Source Water Name	Type of Water	Location
<u>INDIANAPOLIS- 5249004</u>	<u>SW</u>	<u>South Well Fields- Well #2 and Well #9A</u>
<u>PITTSBORO WELL #2</u>	<u>GW</u>	<u>TREATMENT PLANT WELL</u>

#### ***What's in my drinking water before it is treated?***

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of a contaminant does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800)426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
- If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations established limits for contaminants in bottled water which must provide the same protection for public health. The presence of contaminants in drinking water does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Hotline at (800) 426-4791.

#### ***What if I have special health considerations?***

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

#### ***How is the water treated?***

Citizens Water's ground water treatment plants aerate and filter water to remove dissolved iron and manganese. Citizens Water's surface water treatment plants physically remove solids or other contaminants through coagulation, flocculation, sedimentation, and filtration. Chlorine is added to destroy any bacteria present and to maintain a level of disinfectant as the water travels through the distribution systems. Fluoride is added to help strengthen resistance to cavities. A small amount of ammonia is used to minimize byproducts of the disinfection process and to allow chlorine to persist in the system. For a few weeks each year, when the water system is cool, no ammonia is added in order to help maintain good water quality. This chlorine residual without ammonia is known as "free chlorine", which is a more active form of chlorine. It has a more noticeable bleach or chlorine smell with the small level of chlorine.

#### ***What is Cryptosporidium?***

Cryptosporidium is a microscopic organism that lives in the intestines of animals and people. When ingested, this microscopic pathogen may cause a disease called cryptosporidiosis, which has flu-like symptoms. Although there has been no cryptosporidium found in treated finished drinking water, it is found in source water such as White River, Fall Creek, and Eagle Creek Reservoir. Citizens Water utilizes a stringent monitoring program, testing source water and finished drinking water, as well as using online monitors that measure the clarity of water, which helps determine the likelihood of the microbes presence in the drinking water prior to sending it out to purchase water systems.

#### ***How hard is my water?***

As common with water in this region, Citizens Water is considered hard due to the natural levels of minerals calcium and magnesium. The water hardness, expressed as calcium carbonate, typically ranges from 200 to 350 milligrams per liter or parts per million (ppm). This equates to 12 to 20 grains per gallon (the measure often referred to in determining water softener levels). Water hardness can vary depending on water source.

#### ***What can I do to conserve water?***

Plenty! Water conservation measures taken today are critical to ensuring an adequate supply of treatable drinking water in the future. Simple steps you can take at home and in the office can go a long way to reducing your bill and, just as important, conserving water. Don't let the water run when you're brushing your teeth or shaving, run dishwashers and washing machines only when they're full, use a shut-off nozzle on your garden hose, and use a broom (not a hose!) to clean driveways and sidewalks. You should regularly check toilets and faucets for leaks. And, listen to your lawn, it doesn't need as much water as you might think. Set automatic sprinklers to run every other day at most. A good thorough soaking once or twice a week is all your lawn needs to thrive. And take advantage of technology available to turn your irrigation system off when it's raining. Following these tips can save hundreds of gallons of water every month.

**Water Quality Test Results**

The Pittsboro Water Company routinely monitors for contamination in your drinking water according to federal and state laws. This table shows the results sampled by the town during the monitoring period of January 1 to December 31, 2022 or the last mandatory sampling period:

Lead and Copper								
Contaminants	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over AL	Units	Violation	Possible or Suspected Source: (Where did it come from?)
Copper	2022	1.3	1.3	.79	20	ppm	NO	Corrosion of customer plumbing
Lead	2022	0	15	<2.0	20	ppm	NO	Corrosion of customer plumbing
Microbiological Contaminants								
Contaminant:	MCLG: (goal)	MCL, TT or AL: (amount allowed)	Levels Found: (detected results system wide)	Compliance Achieved? For all of 2022	Possible or Suspected Source: (Where did it come from?)			
Coliform, E. coli	0	0	0	YES	Human and animal fecal waste			
Total Coliform	0	0	0	YES	Naturally present in environment			
Disinfection Byproducts								
Disinfectants and Disinfection By Products								
Contaminant	Collection Date	Highest level Detected	Range of Levels Detected	MCLG	MCL	Violation	Likely Source of Contamination	
Chlorine (total)	2022	1	(1-1 ppm)	4ppm	MRDL=4	No	Water additive used to control microbes	
HAA5 (ppb) Haloacetic Acids	2022	19.8 ppb	0-28.7 ppb	No goal	60 ppb	No	Byproducts of disinfection with chlorine	
TTHMs (ppb) Trihalomethanes	2022	70.7	25.8 -53.3 ppb	No goal	80 ppb	No	Byproducts of disinfection with chlorine	
Inorganic Contaminants								
Barium	2022	0.19 ppm	0.19 -0.19	2	2	No	Discharge of drilling wastes; discharges from metal refineries; erosion of natural deposits	
Fluoride	2022	0.698 ppm	0.698 -0.698	4	4.0	No	erosion of natural deposits; water additives which promote strong teeth; discharge from fertilizers	
Combined Radium 226/228	2022	1.72 pCi/L	0 - 1.72 pCi/L	0	5	NO	Corrosion of custom	
Volatile Organic Contaminants								
Xylenes	2022	.00084 ppm	0 - .00084	10	10	NO	Discharge from petroleum factories; discharge from chemical factories	

This table shows the results sampled by Citizens Water during the monitoring period of January 1 to December 31, 2022:

Section I – Contaminants Detected (Treated Drinking Water Data)						
Contaminant:	MCLG: (goal)	MCL, TT or AL:(amount allowed)	Max of all samples	Levels Found: average and detected results system wide	Compliance Achieved?	Possible or Suspected Source: (Where did it come from?)
Regulated Contaminants (Sampled at Treatment Plants)						
Arsenic (ppb)	0 ppb	10 ppb	ND	ND	Yes	Natural Deposits
Barium (ppm)	2 ppm	2 ppm	. ppm	0.13 ppm (0.040- 0.25 ppm)	YES	Natural Deposits
Fluoride (ppm)	4 ppm	4 ppm	.98 ppm	0.71 ppm (0.12 - 0.98 ppm)	YES	natural deposits & treatment additive
Nitrate (ppm)	10 ppm	10 ppm	1.6 ppm	0.69 ppm (ND –3.6 ppm)	YES	Fertilizer, septic tank leachate
Selenium (ppb)	50 ppb	50 ppb	ND	ND	YES	Discharge from petroleum refineries; natural deposits; discharge from mines
Atrazine (ppb)	3 ppb	3 ppb (RAA)	.89 ppb (RAA)	BDL (ND- 0.89 ppb)	YES	Herbicide runoff
Simazine (ppb)	4 ppb	4 ppb	.81 ppb	BDL (ND – .81 ppb)	YES	Herbicide Runoff
1,2,4-Trichlorobenzene (ppb)	70 ppb	70 ppb	.14 ppb	BDL (ND- .14 ppb)	YES	Herbicide Runoff
Xylenes, Total (ppm)	10 ppm	10 ppm	.000291 ppm	ND-.000291 ppm	YES	Discharge from petroleum & chemical factories
Lead and Copper						
Copper (ppm) (2022)	1.3 ppm	1.3 ppm	1.0 ppm	.27 ppm is the 90 <sup>th</sup> percentile (0 of 73>AL)	YES	Corrosion of customer plumbing
Lead (ppb) (2022)	0 ppb	0.015 ppb	32 ppb	9.1 ppb 90 <sup>th</sup> percentile (2 of 73>AL)	YES	Corrosion of customer plumbing
Disinfection Byproducts						
Total Trihalomethanes (TTHMs)	N/A	80 ppb	66 ppb	56 (26 -90 ppb)	YES	Byproducts of disinfection with chlorine
Halo acetic acids (HAAs)	N/A	60 ppb	49 ppb	42 ppb (15-69 ppb)	YES	Byproducts of disinfection with chlorine
Turbidity						
Turbidity (% below TT)	N/A	95%<0.3 NTU	.18 NTU	0.032 (0.020-.18 NTU)	YES	Soil Runoff
Other Organics						
Radionuclides (2019 data)						
Combine Radium 226 & 228	0 pCi/L	5 pCi/L	.80 pCi/L	0.5- 0.80 pCi/L	YES	Erosion of natural deposits
Gross alpha excluding radon and uranium	0	15	2.0 pCi/L	ND – 2.0 pCi/L	YES	Erosion of natural deposits

**Definitions:**

**Action Level Goal or ALG:** The level of a contaminant in drinking water below which there is no known or expected.

**Action Level or AL:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level or MCL:** The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best Available treatment technology.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect or MRDLG: the benefits of the use of disinfectants to control microbial contaminants.

**Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.

**Average or Avg:** Regulatory compliance with some MCLs are based in running annual average of monthly samples.

**ppm:** milligrams per liter or parts per million- or one ounce in 7,350 gallons of water.

**ppb:** micrograms per liter or parts per billion – or one ounce in 7, 350,000 gallons of water.

**NA:** not applicable

**ND:** not detected

**Treatment Technique or TT:**

A required process intended to reduce the level of a contaminant in drinking water.

**Variations and Exemptions:** State or EPA permission not to meet an MCL or treatment technique under certain conditions.

**Turbidity:** The measure of the cloudiness of water. Citizens Water monitors turbidity as it is a good indicator of the effectiveness of the filtration system.

Secondary Drinking Water Standards & Unregulated Parameters						
Contaminant:	MCLG: (goal)	MCL, TT or AL:(amount allowed)	Max of all samples	Levels Found: average and detected results system wide	Compliance Achieved?	Possible or Suspected Source: (Where did it come from?)
Aluminum (ppm)	N/A	200 ppb	110 ppb	30 ppb (ND - 110 ppb)	N/A	Natural deposits; water treatment additive
Chloride (ppm)	N/A	250 ppm	180 ppm	72 ppm (21 -180 ppm)	N/A	Natural deposits; water treatment additive
Hardness (ppm)	N/A	N/A	487 ppm	314 ppm (147 -487 ppm)	N/A	Erosion of natural deposits; leaching
Iron (ppm)	N/A	.3 ppm	.12 ppm	BDL (ND-0.12 ppm)	N/A	Erosion of natural deposits; leaching
Manganese (ppm)	N/A	0.05 ppm	.00040 ppb	BDL (ND-.00040 ppm)	N/A	Erosion of natural deposits; leaching
Metolachlor (ppb)	N/A	N/A	2.1 ppb	BDL (ND -2.1 ppb)	N/A	Herbicide runoff
Nickel (ppb)	N/A	N/A	2.1 ppb	BDL (ND -2.1 ppb)	N/A	Erosion of natural deposits; leaching
pH (Standard Units)	N/A	6.5 - 8.5	8.3	7.8 (7.3 -8.3)	N/A	N/A
Sodium (ppm)	N/A	N/A	160 ppm	46 ppm (13 -160 ppm)	N/A	Erosion of natural deposits; leaching
Sulfate (ppm)	N/A	250 ppm	178 ppm	45 ppm (6.8-178 ppm)	N/A	Erosion of natural deposits; leaching
Zinc (ppm)	N/A	5000 ppb	ND	ND	N/A	Erosion of natural deposits; leaching
<b>Residual Disinfectants</b>						
Chlorine (MRDL)	4 ppm	4ppm	2.8	1.90 ppm (0 – 2.8 ppm)	YES	Water additive used to control microbes
<b>Microbiological Contaminants</b>						
Coliform, E. coli	0	1	ND	ND	YES	Human And animal fecal waste
Total Coliforms	N/A	5.0%	.63 %	.15% (0% - .63 %)	YES	Naturally present in environment
<b>Untreated Source Water</b>						
Cryptosporidium (org/10L)	N/A	N/A	10	1.8 (ND-10 oocysts/10L)	N/a	Removed during treatment
Giardia (org/10L)	N/A	N/A	86	10( ND – 86 oocysts/10L)	N/A	Removed during treatment
TOC (Untreated Water)	N/A	N/A	3.9 ppm	7.1 ppm (2.6 – 7.1 ppm)	N/A	Naturally present in the environment

\*Untreated source water data (in order) from the following plant intakes: White River/ Fall Creek/ T.W. Moses/ White River North